Nilawar Laboratories
(A Unit of MNEC Consultants Pvt. Ltd)

ISO 9001:2015
ISO 14001:2015
ISO 45001:2018

CIN No. U74140MH2009PTC196108

TEST REPORT

Test Report No	: NL/WATER/588	**Remark**	: --
Customer Name & Address	: St. Vincent Pallotti School opp. Indian oil Petrol Pump, Kamptee Kalmana Road ,Ranala Kamptee	**Contact Details**	: 9657036561
		Sampling Method / Plan Details *(If applicable)*	: NA
Sample Collected On	: Date 10/02/2025 Time 10.30 am	**Sample Details**	: Drinking Water Sample
Sample Received On	: Date 10/02/2025 Time 2.20pm	**Sampling Done By**	: Customer
Sample Condition	: Preserved (Yes/No/NA) : NA	**Sealed : Yes**	: Acceptable : Yes
Period of Testing	: 11/02/2025 to 14/02/2025	**Report Issue Date**	: 15/02/2025
Sample ID. *(By Lab)*	: NL-0499/FEB25/WA-01	**Sample ID.** *(By Customer)*	: WA-01-Drinking Water Sample

1. Chemical Testing
III. Water

TEST RESULTS

Sr. No.	Test Parameters	Results	Units	Test Method Used	As per IS 10500 : 2012	
					Acceptable	Permissible
1.	Total coliform	Absent	-	IS 15185	Shall not be detectable in any 100 ml Sample	
2.	Thermotallerant Coliform	Absent				
3.	E- Coli	Absent				

NR - no relaxation, AG - agreeable; NA- not applicable; BDL-below detection limit

For M/s Nilawar Laboratories,

Dinesh Bangadkar
(Authorized Signatory)

Checked By,

Priti Mahalle
(Deputy Technical Manager)

Note:-
1. *This report should not be reproduced wholly or in part and not to be used as evidence in any court of law without written approval from Nilawar Laboratories.*
2. *The results listed referred to the tested samples and applicable parameters only. Results represent the sample as received.*
3. *Our liability is limited to the commercial value of the test/tests carried out.*
4. *Any discrepancy in test report should be reported within 15 days from the report issue date.*
5. *Subject to Nagpur jurisdiction only.*

---------- *End of Report* ----------

Off. : First Floor, 'Pratibha Sankul' Beside Alankar Cinema, Dharampeth, Nagpur - 10. Ph. : +91-712-2542261, 2542291, E-mail :nilawarlabs@gmail.com
Laboratory : At Km 16.5, Nilawar Motors Complex, Amravati Road, Waddhamna, Nagpur - 440 023. Mob. : +91-9922409055, 9552550955

➤ Soil Testing for all types of Foundation Designs. ➤ Chemical Analysis of Soil & Water ➤ Mechanical Analysis of Soil & Rock
➤ Micro-biological Analysis of Soil & Water ➤ Testing of Construction Material ➤ Environment Consultants ➤ Environment Monitoring & Analysis

Nilawar Laboratories
(A Unit of MNEC Consultants Pvt. Ltd)

NABL ACCREDITED LAB VIDE - TC-9782
CIN No. U74140MH2009PTC196108

TC-9782

TEST REPORT

Test Report No	: NL/WATER/587	ULR No.	: TC978225000000355F
Customer Name & Address	: St. Vincent Pallotti School opp. Indian oil Petrol Pump, Kamptee Kalmana Road ,Ranala Kamptee	Contact Details	: 9657036561
		Sampling Method / Plan Details *(If applicable)*	: NA
Sample Collected On	: Date 10/02/2025 Time 10.30 am	Sample Details	: Drinking Water Sample
Sample Received On	: Date 10/02/2025 Time 2.20pm	Sampling Done By	: Customer
Sample Condition	: Preserved (Yes/No/NA) : NA	Sealed : Yes	: Acceptable : Yes
Period of Testing	: 11/02/2025 to 14/02/2025	Report Issue Date	: 15/02/2025
Sample ID. *(By Lab)*	: NL-0499/FEB25/WA-01	Sample ID. *(By Customer)*	: WA-01-Drinking Water Sample

1. Chemical Testing
III. Water

TEST RESULTS

Sr. No.	Test Parameters	Results	Units	Test Method Used	As per IS 10500 : 2012	
					Acceptable	Permissible
1.	Colour	2.0	-	IS 3025 (Part 4)	5	15
2.	Odour	AG	-	IS 3025 (Part 5)	Agreeable	Agreeable
3.	pH at 25 °C	6.81	-	IS 3025 (Part11)	6.5-8.5	No Relaxation
4.	Turbidity	0.2	NTU	IS 3025 (Part10)	1.0	5.0
5.	Total Dissolved Solids (TDS)	302	mg/l	IS 3025 (Part16)	500	2000
6.	Total Alkalinity as CaCO3	35	mg/l	IS 3025 (Part 23)	200	600
7.	Total Hardness as CaCO3	10	mg/l	IS 3025 (Part 21)	200	600
8.	Calcium as Ca	2.4	mg/l	IS 3025 (Part 40)	75	200
9.	Magnesium as Mg	0.976	mg/l	APHA 24th Edition	30	100
10.	Chloride as Cl	24.9	mg/l	IS 3025 (Part32)	250	1000
11.	Nitratre as NO_3	0.409	mg/l	APHA 24th Edition	45	No Relaxation
12.	Fluoride as F	BDL	mg/l	APHA 24th Edition	1.0	1.5
13.	Iron as Fe	BDL	mg/l	IS 3025 (Part53)	0.3	No Relaxation

NR - no relaxation, AG - agreeable; NA- not applicable; BDL-below detection limit

For M/s Nilawar Laboratories,

Dinesh Bangadkar
(Authorized Signatory)

Checked By,

Priti Mahalle
(Deputy Technical Manager)

Note:-

1. *This report should not be reproduced wholly or in part and not to be used as evidence in any court of law without written approval from Nilawar Laboratories.*
2. *The results listed referred to the tested samples and applicable parameters only. Results represent the sample as received.*
3. *Our liability is limited to the commercial value of the test/tests carried out.*
4. *Any discrepancy in test report should be reported within 15 days from the report issue date.*
5. *Subject to Nagpur jurisdiction only.*

End of Report

Off. : First Floor, 'Pratibha Sankul' Beside Alankar Cinema, Dharampeth, Nagpur - 10. Ph. : +91-712-2542261, 2542291, E-mail : nilawarlabs@gmail.com
Laboratory : At Km 16.5, Nilawar Motors Complex, Amravati Road, Waddhamna, Nagpur - 440 023. Mob. : +91-9922409055, 9552550955

➤ Soil Testing for all types of Foundation Designs ➤ Chemical Analysis of Soil & Water ➤ Mechanical Analysis of Soil & Rock
➤ Micro-biological Analysis of Soil & Water ➤ Testing of Construction Material ➤ Environment Consultants ➤ Environment Monitoring & Analysis

APPENDIX VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 828 Date: - 23/06/2025

It is certified that an inspection team headed by Dr Hemant Hirwase (Name of Officer with designation) from Health Department (Name of Department /Office) inspected St. Vincent Pallotti School Ramala of School & Address) on 23/06/25 and found that St. Vincent Pallotti School (Name of School) has safe drinking water facilities for students and member of staff of the institution and is maintaining the hygenic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/UT Govt.

The above valid for a period of 1 years

Signature with Seal :

Name :

Designation : तालुका आरोग्य अधिकारी तालुका-नागपूर (ग्रामीण) जिल्हापरिषद-नागपूर

To,

The Principal
St. Vincent Pallotti School
Ramala Kamptee, Nagpur.

(Name & Address of Institution)

Scanned with OKEN Scanner